

**WATER QUALITY REPORT  
BEAVER HOLLOW, SANDOWN, NH  
EPA # 2082010**

**VOLATILE ORGANIC CONTAMINANTS (b) (Units µg/L)**

Analyte	Results	MCL	Date	Analyte	Results	MCL	Date
1,1,1,2-Tetrachloroethane	< 0.5	NR	2/9/11	cis-1, 2-Dichloroethylene	< 0.5	70	2/9/11
1,1,1-Trichloroethane	< 0.5	200	2/9/11	cis-1, 3-Dichloropropylene	< 0.5	NR	2/9/11
1,1,2,2-Tetrachloroethane	< 0.5	NR	2/9/11	Dibromochloromethane	1.6	80	2/9/11
1,1,2-Trichloroethane	< 0.5	5	2/9/11	Dibromomethane	< 0.5	NR	2/9/11
1,1-Dichloroethane	< 0.5	NR	2/9/11	Dichlorodifluoromethane	< 0.5	NR	2/9/11
1,1-Dichloroethane	< 0.5	7	2/9/11	Diethyl ether	< 0.5	NR	2/9/11
1,1-Dichloropropylene	< 0.5	NR	2/9/11	Diisopropyl Ether (DIPE)	< 0.5	NR	2/9/11
1,2,3-Trichlorobenzene	< 0.5	NR	2/9/11	Ethyl Tert-Butyl Ether (ETBE)	< 0.5	NR	2/9/11
1,2,3-Trichloropropane	< 0.5	NR	2/9/11	Ethylbenzene	< 0.5	700	2/9/11
1,2,4-Trichlorobenzene	< 0.5	70	2/9/11	Hexachlorobutadiene	< 0.5	NR	2/9/11
1,2,4-Trimethylbenzene	< 0.5	NR	2/9/11	Isopropylbenzene	< 0.5	NR	2/9/11
1,2-Dibromo - 3- chloropropane	< 0.5	0.2	2/9/11	m/p - Xylenes	< 0.5	NR	2/9/11
1,2-Dibromoethane	< 0.5	NR	2/9/11	Methyl ethyl ketone (MEK) 2-Butanone	<10	NR	2/9/11
1,2-Dichlorobenzene	< 0.5	600	2/9/11	Methylene chloride	< 0.5	5	2/9/11
1,2-Dichloroethane	< 0.5	5	2/9/11	Methyl-t-butyl-ether (MtBE)	< 0.5	13	2/9/11
1,2-Dichloropropane	< 0.5	5	2/9/11	Napthalene	< 0.5	NR	2/9/11
1,3,5-Trimethylbenzene	< 0.5	NR	2/9/11	n-Butylbenzene	< 0.5	NR	2/9/11
1,3-Dichlorobenzene	< 0.5	NR	2/9/11	Nitrobenzene	<10	NR	2/9/11
1,3-Dichloropropane	< 0.5	NR	2/9/11	n-Propylbenzene	< 0.5	NR	2/9/11
1,4-Dichlorobenzene	< 0.5	75	2/9/11	o-Xylene	< 0.5	NR	2/9/11
2,2-Dichloropropane	< 0.5	NR	2/9/11	sec Butylbenzene	< 0.5	NR	2/9/11
2-Chlorotoluene	<0.5	0.5	2/9/11	Styrene	< 0.5	100	2/9/11
2-Hexanone	<10	NR	2/9/11	Tert-Amyl Methyl Ether (TAME)	< 0.5	NR	2/9/11
4 Methyl-2-Pentanone (MIBK)	<10	NR	2/9/11	Tert-Butyl Alcohol (TBA)	<10	NR	2/9/11
4-Chlorotoluene	<0.5	0.5	2/9/11	Tert-Butylbenzene	< 0.5	NR	2/9/11
4-Isopropyltoluene	< 0.5	NR	2/9/11	Tetrachloroethylene	< 0.5	5	2/9/11
Acetone	<10	NR	2/9/11	Tetrachloromethane	< 0.5	NR	2/9/11
Benzene	< 0.5	5	2/9/11	Tetrahydrofuran	<10	NR	2/9/11
Bromobenzene	< 0.5	NR	2/9/11	Toluene	< 0.5	1000	2/9/11
Bromochloromethane	< 0.5	NR	2/9/11	Total Trihalomethanes	5.2	80	2/9/11
Bromodichloromethane	0.8	80	2/9/11	Total Xylenes	< 0.5	10,000	2/9/11
Bromoform	2.8	80	2/9/11	Trans-1, 2-Dichloroethylene	< 0.5	100	2/9/11
Bromomethane	< 0.5	NR	2/9/11	Trans-1, 3-Dichloropropylene	< 0.5	NR	2/9/11
Carbon Disulfide	< 0.5	NR	2/9/11	Trichloroethylene	< 0.5	5	2/9/11
Chlorobenzene	< 0.5	100	2/9/11	Trichlorofluoromethane	< 0.5	NR	2/9/11
Chloroethane	< 0.5	NR	2/9/11	Vinyl chloride	< 0.5	2	2/9/11
Chloroform	< 0.5	80	2/9/11				
Chloromethane	< 0.5	NR	2/9/11				
				<b>DISINFECTION BY-PRODUCTS (a)</b>			
				Total Trihalomethanes	7	80	8/9/10
				Haloacetic Acids	1.2	60	8/9/10

**SYNTHETIC ORGANIC CONTAMINANTS (b) (Units µg/L)**

	Results	MCL	Date		Results	MCL	Date
1, 2-Dibromo-3-chloropropane (DBCP)	< 0.02	0.2	2/4/08	Endrin	< 0.1	2	2/4/08
2,4,5-TP (Silvex)	< 0.25	50	2/4/08	Ethylene dibromide (EDB)	< 0.02	0.05	2/4/08
2,4-D	< 1	70	2/4/08	Glyphosate	< 10	700	2/4/08
3-Hydroxycarbofuran	< 1	NR	2/4/08	Heptachlor	< 0.1	0.4	2/4/08
Alachlor	< 0.1	2	2/4/08	Heptachlor Epoxide	< 0.1	0.2	2/4/08
Aldicarb	< 1	NR	2/4/08	Hexachlorobenzene	< 0.1	1	2/4/08
Aldicarb Sulfone	< 1	NR	2/4/08	Hexachlorocyclopentadiene	< 0.1	50	2/4/08
Aldicarb Sulfoxide	< 1	NR	2/4/08	Lindane	< 0.1	0.2	2/4/08
Aldrin	< 0.1	NR	2/4/08	Methiocarb	< 1	7	2/4/08
Atrazine	< 0.1	3	2/4/08	Metolachlor	< 0.1	40	2/4/08
Benzo(a)pyrene	< 0.1	0.2	2/4/08	Methomyl	< 1	NR	2/4/08
Butachlor	< 0.1	NR	2/4/08	Methoxychlor	< 0.1	40	2/4/08
Carbaryl	< 1	NR	2/4/08	Metribuzin	< 0.1	NR	2/4/08
Carbofuran	< 1	40	2/4/08	Oxamyl (Vydate)	< 1	200	2/4/08
Chlordane	< 0.4	2	2/4/08	Pentachlorophenol	< 0.1	1	2/4/08
Di (2-ethylhexyl) adipate	< 1	400	2/4/08	Picloram	< 0.5	500	2/4/08
Di (2-Ethylhexyl) phthalate	< 1	6	2/4/08	Propachlor	< 0.1	NR	2/4/08
Dicamba	< 0.5	NR	2/4/08	Propoxur (Baygon)	< 1	NR	2/4/08
Dieldrin	< 0.1	NR	2/4/08	Simazine	< 0.1	4	2/4/08
Dinoseb	< 1	7	2/4/08	Toxaphene	< 2	3	2/4/08

**WATER QUALITY REPORT  
BEAVER HOLLOW, SANDOWN, NH  
EPA # 2082010**

**INORGANIC CONTAMINANTS (b)**

Analyte	Results	MCL	Date
Antimony (µg/L)	< 2	6	2/9/11
Arsenic (µg/L)	< 2	10	2/9/11
Barium (mg/L)	0.093	2	2/9/11
Beryllium (µg/L)	< 2	4	2/9/11
Cadmium (µg/L)	< 2	5	2/9/11
Chromium (µg/L)	< 10	100	2/9/11
Cyanide (µg/L)	< 20	200	2/4/08
Fluoride (mg/L)	1.6	4	2/9/11
Mercury (µg/L)	0.1	2	2/9/11
Nickel (µg/L)	< 10	100	2/9/11
Nitrate-N (mg/L)	<0.20	10	2/9/11
Nitrite-N (mg/L)	< 0.05	1	2/9/11
Selenium (µg/L)	< 5	50	2/9/11
Thallium (µg/L)	< 1	2	2/9/11

**FIRST DRAW LEAD AND COPPER (a)**

Analyte	Results	AL	Date
Lead (µg/L) 90th percentile sample	< 5	15	2009
Copper (mg/L) 90th percentile sample	0.026	1.3	2009

**Microbiological Contaminants (a)**

Microbiological Contaminants (a)	Results	MCL
Total Coliform	Absent	≤1/month
E. coli	Absent	Absent
Average Chlorine Residual (mg/L)	0.55	

**SECONDARY CONTAMINANTS (b) - AESTHETIC**

Analyte	Results	SMCL	Date
Chloride (mg/L)	74	250	2/9/11
Fluoride (mg/L)	1.6	2	2/9/11
Iron (mg/L)	<0.01	0.3	2/9/11
Manganese (mg/L)	< 0.01	0.05	2/9/11
pH (Standard Units)	8.14	6.5 – 8.5	2/9/11
Silver (µg/L)	< 4	100	2/4/08
Sodium (mg/L)	49.2	100-250	2/9/11
Sulfate (mg/L)	19	250	2/9/11
Zinc (mg/L)	0.094	5	2/9/11

**RADIOLOGICAL CONTAMINANTS (b)**

Analyte (Units)	Results	MCL	Date
Compliance Gross Alpha (pCi/L)	<2.0	15	10/30/08
Radon Gas (pCi/L)	1080	None	4/19/11
Radium-226 (pCi/L)	0.1	5	10/30/08
Radium-228 (pCi/L)	<0.3	5	10/30/08
Uranium (µg/L)	<0.06	30	10/30/08

**UNREGULATED CONTAMINANTS (b)**

Analyte (Units)	Results	Date
Alkalinity as CaCO <sub>3</sub> (mg/L)	92.6	2/4/08
Calcium (mg/L)	30.7	2/9/11
Copper (mg/L)	< 0.01	2/9/11
Hardness, Total as CaCO <sub>3</sub> (mg/L)	99.7	2/9/11
Hydrogen Sulfide (mg/L)	< 0.02	2/4/08
Lead (µg/L)	< 5	2/4/08
Magnesium (mg/L)	5.6	2/9/11
Specific Conductance (umhos/cm <sup>2</sup> )	523.8	5/20/08
Sulfide (mg/L)	< 0.2	2/4/08

**SOURCE WATER AND TREATMENT INFORMATION**

**Water Source:** One bedrock well.

**Treatment:** Chlorination for disinfection; filtration to remove iron and manganese.

**KEY TO ABBREVIATIONS**

**AL** Action Level - The concentration of a contaminant which, if exceeded triggers treatment of or other requirements which a water system must follow.

**MCL** Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water.

**SMCL** Secondary Maximum Contaminant Level - The highest level of a contaminant that affects the aesthetic characteristics ( taste, odor, or color) of drinking water.

**NR** Not Regulated - Contaminants test for but not regulated by the State or EPA.

**(a)** samples taken from the distribution system.

**(b)** samples taken from the distribution entry point.

**mg/L** milligrams per Liter or parts per million.

**µg/L** micrograms per Liter or parts per billion.

**pCi/L** picocuries per Liter (measure of radioactivity)

**N/A** Not Applicable    **nd** not detected    **BDL** Below Detection Level    **≤** Less Than or Equal To    **<** Less Than

**CONTACT INFORMATION**

If you have any questions about this report, or about your water quality, please call Gary Tetley, Water Quality Manager, at 1-603-913-2378 or 1-800-553-5191.

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.