

**PENNICHUCK WATER WORKS
WATER QUALITY REPORT
PEU / BIRCH HILL EAST
EPA # 0512010**

Pennichuck Water Works (PWW) purchases water from the North Conway Water Precinct (NCWP). PWW is responsible for monthly bacteria testing and Lead and Copper testing once every three years. The NCWP is responsible for testing all other regulated water quality parameters. Additional information regarding your water can be found by visiting NCWP's website <http://ncwpmh.org/wqreports.htm>.

FIRST DRAW LEAD AND COPPER

Analyte	Results	AL	Date
Lead (µg/L) 90th percentile sample	4	15	10/28/10
Copper (mg/L) 90th percentile sample	0.180	1.3	10/28/10

AL - Action Level

MCL -Maximum Contaminant Level

≤ Less Than or Equal To

MICROBIOLOGICAL CONTAMINANTS

ANALYTE	Results	MCL	Date
Total Coliform	Absent	≤ 1/month	Monthly
E. coli	Absent	Absent	Monthly
Average Chlorine Residual (mg/L)	0.35	4	

DISINFECTION BY-PRODUCTS

Total Trihalomethanes	0.6	80	7/12/11
Haloacetic Acids	< 1	60	7/12/11

If you have any questions about this report, or about your water quality, please call 1-603-913-2378 or 1-800-553-5191.

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.