

**PENNICHUCK WATER WORKS
WATER QUALITY REPORT
PEU / BROOK PARK
EPA # 1392060**

Pennichuck Water Works (PWW) purchases water from the city of Manchester. PWW is responsible for quarterly bacteria testing; Lead and Copper testing once every three years; Disinfection Byproduct sampling. The city of Manchester is responsible for testing all other regulated water quality parameters. Additional information regarding your water can be found by visiting Manchester's website:
<http://www.manchesternh.gov/website/Departments/WaterWorks/WaterQuality/tabid/420/Default.aspx>.

FIRST DRAW LEAD AND COPPER

| Analyte | Results | AL | Date |
|--------------------------------------|---------|-----|---------|
| Lead (µg/L) 90th percentile sample | < 5 | 15 | 10/8/09 |
| Copper (mg/L) 90th percentile sample | < 0.01 | 1.3 | 10/8/09 |

MICROBIOLOGICAL CONTAMINANTS

| ANALYTE | Results | MCL | Date |
|----------------|---------|-------------|-----------|
| Total Coliform | Absent | ≤ 1/Quarter | Quarterly |
| E. coli | Absent | Absent | Quarterly |

DISINFECTION BYPRODUCTS

| Analyte | Results | MCL | Date |
|-----------------------------------|---------|--------|---------|
| Total Trihalomethanes (µg/L) | 2 | 80 | 8/28/08 |
| Total Haloacetic Acids (5) (µg/L) | 4 | 60 | 8/28/08 |
| Average Chlorine Residual (mg/L) | 1.01 | 4-MRDL | |

AL - Action Level

MCL -Maximum Contaminant Level

µg/L - micrograms per liter

mg/L - milligrams per liter

MRDL: Maximum Residual Disinfectant Level

If you have any questions about this report, or about your water quality, please call 1-603-913-2378 or 1-800-553-5191.

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.