

**PENNICHUCK WATER WORKS  
WATER QUALITY REPORT  
CABOT PRESERVE  
EPA # 0192070**

Pennichuck Water Works (PWW) purchases water from the Town of Merrimack. PWW is responsible for monthly bacteria testing; Lead and Copper testing once every three years; Disinfection Byproduct sampling. The Town of Merrimack is responsible for testing all other regulated water quality parameters. Additional information regarding your water can be obtained by calling the Merrimack Water District at 603-424-7171.

**FIRST DRAW LEAD AND COPPER**

| Analyte                              | Results | AL  | Date    |
|--------------------------------------|---------|-----|---------|
| Lead (µg/L) 90th percentile sample   | < 5     | 15  | 7/15/08 |
| Copper (mg/L) 90th percentile sample | 0.533   | 1.3 | 7/15/08 |

**MICROBIOLOGICAL CONTAMINANTS**

| ANALYTE        | Results | MCL    | Date    |
|----------------|---------|--------|---------|
| Total Coliform | Absent  | ≤ 1    | Monthly |
| E. coli        | Absent  | Absent | Monthly |

**DISINFECTION BYPRODUCTS**

| Analyte                           | Results | MCL    | Date    |
|-----------------------------------|---------|--------|---------|
| Total Trihalomethanes (µg/L)      | 15      | 80     | 8/26/10 |
| Total Haloacetic Acids (5) (µg/L) | < 1     | 60     | 8/26/10 |
| Average Chlorine Residual (mg/L)  | 0.16    | 4-MRDL |         |

**AL - Action Level**

**MCL -Maximum Contaminant Level**

**µg/L - micrograms per liter**

**mg/L - milligrams per liter**

**MRDL: Maximum Residual Disinfectant Level**

If you have any questions about this report, or about your water quality, please call 1-603-913-2378 or 1-800-553-5191.

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.