

**PENNICHUCK WATER WORKS  
WATER QUALITY REPORT  
REDFIELD ESTATES - DERRY, NH  
EPA # 0612080**

Pennichuck Water Works (PWW) purchases water from the town of Derry and blends the Derry water with water from the Drew Woods Community Water System which consists of six wells.

**FIRST DRAW LEAD AND COPPER**

Analyte	Results	AL	Date
Lead (µg/L) 90th percentile sample	6.5	15	2009
Copper (mg/L) 90th percentile sample	0.370	1.3	2009

**MICROBIOLOGICAL CONTAMINANTS**

ANALYTE	Results	MCL	Date
Total Coliform	Absent	≤ 1/month	Monthly
E. coli	Absent	Absent	Monthly

**DISINFECTION BYPRODUCTS**

Analyte	Results	MCL	Date
Total Trihalomethanes (µg/L)	10	80	8/9/10
Total Haloacetic Acids (5) (µg/L)	1.4	60	8/9/10
Average Chlorine Residual (mg/L)	0.4	4-MRDL	

AL - Action Level

MCL -Maximum Contaminant Level

µg/L - micrograms per liter

mg/L - milligrams per liter

MRDL: Maximum Residual Disinfectant Level

If you have any questions about this report, or about your water quality, please call 1-603-913-2378 or 1-800-553-5191.

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.